

VOC Content Test Certificate

Friday, 7th February 2020

Supplier: CDK Stone Pty Ltd (4-6 Freighter Road, Moorabbin, VIC, 3189, Australia).

Sample Description: Lithofin MN Stain-Stop >ECO<

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.3 13.1.1</p> <p>Green Star Interiors V1.3 12.1.1B</p>	<p>Lithofin MN Stain-Stop</p> <p>>ECO<</p>
<p>Acoustic sealants, architectural sealant, waterproofing membranes and sealants: 250 grams per Litre as VOC content per material</p>	<p>135 gram per Litre as VOC content per material</p>
<p><i>We hereby certify Lithofin MN Stain-Stop >ECO< Sealer is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Dale Duncan
BSc (Hons)
Consultant

V2001057