

# VOC Content Test Certificate

Friday, 7<sup>th</sup> February 2020

Supplier: CDK Stone Pty Ltd (4-6 Freighter Road, Moorabbin, VIC, 3189, Australia).

Sample Description: Lithofin STAINSTOP >W<

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

**Test Data:**

|  |  |
|--|--|
| <p><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Design &amp; As Built V1.3 13.1.1</b></p> <p><b>Green Star Interiors V1.3 12.1.1B</b></p>   | <p><b>Lithofin STAINSTOP &gt;W&lt;</b></p>                   |
| <p>Acoustic sealants, architectural sealant, waterproofing membranes and sealants:<br/>250 grams per Litre as VOC content per material</p>   | <p><b>164 gram per Litre as VOC content per material</b></p> |
| <p><i>We hereby certify Lithofin STAINSTOP &gt;W&lt; Sealer is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p> |  |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Dale Duncan  
BSc (Hons)  
Consultant

V2001057